

IR-03 Pilot Study Update

Cabrera-Insight JV / CDM Smith

BCT Meeting

Hunters Point Naval Shipyard

March 27, 2014

Location: HPNS IR03





HPNS IR03 – Overview



Nonaqueous phase liquid (NAPL) Treatment Pilot Study (NTPS):

Activity	Schedule
In Situ Thermal Remediation (ISTR) Operation	February 4 – May 30, 2014
ISTR Performance Soil and Groundwater Sampling	June 2014
In Situ Solidification/Stabilization (ISS) Design – Draft to BCT	April 16, 2014

ISTR System





Observations Reported at the Last BCT Meeting



- Approximately 370 gallons of NAPL were collected through February
 4, 2014
- Temperatures at most wells reached 90°C within three weeks
 Using a heat exchanger to increase the temperature of injected water has proved to be very efficient
- Pneumatic control of the system was maintained
- Hydraulic gradients towards the treatment system zone were established



ISTR System Operation: New NAPL Separation Tank





New- 10,000 gallon NAPL


ww.adlertankrentals.com


- •Old- 1000 gallon NAPL Separator
- Large volumes of NAPL required longer retention for phase separation.

Separator

Hydraulic Control: February/March







- Each extraction well pumping at an average rate of 0.4 gpm.
- Pumping at a total rate of approximately 5,000 – 12,000 gal/day (~200 – 500 gal/hr).
- Total pumped volume up to approximately 345,000 gallons through 03/19/14.
- Pressures within the system are low; pneumatic control is maintained.









Figure 1

Model-Estimated Capture Zone, First Month of ISTR Operation




Temperatures in Treatment System






LNAPL Production





DNAPL Production





Summary



- As of 3/19/2014:
 - -345,000 gallons of water have been recirculated.
 - -1200 gallons of NAPL have been extracted.
- Significant amounts of NAPL are still being extracted.
 - –We're in the process of incorporating VGAC and LGAC data into the LNAPL production
 - -TO-15 data is in the process of validation
- Operations will continue with temperatures slowly ramping up to boiling.
- Criteria for shutting down ISTR system:
 - –Cessation of NAPL recovery
 - –Minimum number of pore volumes (at least 3) recirculated with no NAPL recovery.



